



TRAY CABLE 600V

Control, Unshielded, E-1 or E-2 Color Code

UL 44, UL 1277, ICEA-S-95-658/NEMA WC70

Control cable

APPLICATIONS

- In free air, cable trays, raceways or direct burial
- In wet or dry locations
- Permitted for Exposed Run - TC-ER
- Other industrial applications



CONSTRUCTION

Conductors	Tinned copper conductor in accordance with ASTM B-3 or ASTM B-33 , class B in accordance with ASTM B- 8.
Insulation	EPR type EPCV compound fulfilling type XHHW-2 (rating VW-1)
Colour code	Per ICEA Method 1 Table E-1* or Method 1Table E-2 *) For more than 21 conductors the color sequence be repeated as necessary.
Core arrangement	Insulated conductors are assembled round together. If needed rubber fillers can be used in interstices for selected constructions.
Separator	Synthetic tape over core of cable .
Outer jacket	CPE-Heavy duty flame retardant thermosetting chlorinated polyethylene.
Colour of outerjacket	Black.
Test voltage	According to tab 14.1-UL 1277.

Features

Excellent flame resistant: FT4 UL 1685	Excellent resistance to crush, compression cuts and heat deformation
Maximum conductor temperature: 90°C	Moisture, water, weather, sunlight resistant
Excellent physical, thermal and electrical properties	Minimum bending radius: D- overall diameter of cable
Excellent resistant to a low temperature: - 40°C	D < 1 in. 4 x D
Meets cold bend test at -25°C	1 in. < D < 2 in. 5 x D
Oil resistant: UL 1277	D > 2 in. 6 x D
Ozone resistant: EN 60811-403, method A	All materials comply with ROHS and REACH declarations

TRAY CABLE 600V

Approvals

UL: E310468

Example of marking
Ink jet printed

TF CABLE (UL) E310468 FLEXTREME TC TYPE TC-ER XHHW-2 cdrs 600V 3/C 14AWG 90°C (194F) wet or dry
Sun Res Oil Res I & II FT4 -40°C dir bur + footage marking

14AWG

Number of conductors	Conductor Size	Conductor stranding	Nominal insulation thickness	Nominal jacket thickness	Approx. O.D.	Approx. weight
N	AWG	N	mils	mils	inch	LBS/1000ft
2	14	7	30	55	0,4	90
3	14	7	30	55	0,4	109
4	14	7	30	55	0,4	134
5	14	7	30	55	0,5	161
7	14	7	30	70	0,6	236
9	14	7	30	70	0,7	306
12	14	7	30	70	0,7	343
19	14	7	30	90	0,9	557
25	14	7	30	90	1	687
30	14	7	30	90	1	789
37	14	7	30	90	1,2	969

TRAY CABLE 600V

12AWG

Number of conductors	Conductor Size	Conductor stranding	Nominal insulation thickness	Nominal jacket thickness	Approx. O.D.	Approx. weight
N	AWG	N	mils	mils	inch	LBS/1000ft
2	12	7	30	55	0,42	115
3	12	7	30	55	0,44	141
4	12	7	30	55	0,48	175
5	12	7	30	55	0,52	212
7	12	7	30	70	0,64	310
9	12	7	30	70	0,74	403
12	12	7	30	70	0,77	458
19	12	7	30	90	0,99	741
25	12	7	30	90	1,12	921
30	12	7	30	90	1,15	1064
37	12	7	30	90	1,29	1308

10AWG

Number of conductors	Conductor Size	Conductor stranding	Nominal insulation thickness	Nominal jacket thickness	Approx. O.D.	Approx. weight
N	AWG	N	mils	mils	inch	LBS/1000ft
2	10	7	30	55	0,47	156
3	10	7	30	55	0,49	194
4	10	7	30	70	0,57	258
5	10	7	30	70	0,62	313
7	10	7	30	70	0,72	431
9	10	7	30	70	0,83	563
12	10	7	30	90	0,91	682

TRAY CABLE 600V

Method 1 Table E-1

Conductor Number	Base Color	Tracer Color
1	Black	–
2	White	–
3	Red	–
4	Green	–
5	Orange	–
6	Blue	–
7	White	Black
8	Red	Black
9	Green	Black
10	Orange	Black
11	Blue	Black
12	Black	White
13	Red	White
14	Green	White
15	Blue	White
16	Black	Red
17	White	Red
18	Orange	Red
19	Blue	Red
20	Red	Green
21	Orange	Green

Method 1 Table E-2

Conductor Number	Base Color	Tracer Color
1	Black	–
2	Red	–
3	Blue	–
4	Orange	–
5	Yellow	–
6	Brown	–
7	Red	Black
8	Blue	Black
9	Orange	Black
10	Yellow	Black
11	Brown	Black
12	Black	Red
13	Blue	Red
14	Orange	Red
15	Yellow	Red
16	Brown	Red
17	Black	Blue
18	Red	Blue
19	Orange	Blue
20	Yellow	Blue
21	Brown	Blue

The information contained in this document, including the tables and drawings, are provided for illustrative purposes only and not a commercial offer; nor may it constitute the basis for pursuing any claim against TELE-FONIKA Kable SA. The suitability of any product including properties, should be made by a qualified person; having already gained the appropriate permissions and documentation, to ensure compliance with any applicable law or regulation.